



Product Service

CERTIFICATE

No. Z1 15 10 43792 003

Holder of Certificate: **MP Gamma S.r.l.**
Via Cisa Ligure 115/117
42041 Lentigione di Brescello (RE)
ITALY



Certification Mark:



Product: **Storage equipment and devices
(Empty enclosures)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: MEC15068.00

Valid until: 2020-10-15

Date, 2015-10-19


(Gianpaolo Mensa)



Page 1 of 2



Product Service

CERTIFICATE

No. Z1 15 10 43792 003

Model(s): SD Series, SDN Series, SPN Series, BK Series, SCS Series, SCSX Series, EMP Series, EMPX Series, CP Series, CPN Series, CLN Series, KC Series, KCS Series

Parameters:

Dimensions From - To [WxHxD (mm)]: 80x80x70 - 600x600x250 (SD, SDN, SPN Series); 350x250x220 - 600x400x250 (BK Series); 600x1200x400 - 1600x2200x800 (SCS, SCSX, EMP, EMPX Series); 200x200x150 - 1000x1200x400 (CP, CPN, CLN Series); 300x300x85 - 600x750x250 (KC Series); 300x300x80 - 600x750x140 (KCS Series)

IP Grade: IP66 (SD, SCS, SCSX, EMP, EMPX Series) IP66, IP67, IP69K (SDN, SPN, CPN Series) IP66, IP69K (BK, CP, CLN, KC, KCS Series)

IK Grade: IK10

Material: Stainless Steel Spx.: 1,0 mm - 1.2 mm; 1.5 mm; 2,0 mm.

Note: Series SCS; SCSX; EMP; EMPX equipped with one or two doors.

Tested according to: EN 62208:2012
EN 60529:1997/A2:2014

Production Facility(ies): 93829

Page 2 of 2



Product Service