



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres for rules and details of the IECEX Scheme visit [www.iecex.com](http://www.iecex.com) **Ex COMPONENT CERTIFICATE**

Certificate No.: **IECEX FIDI 23.0007U** Page 1 of 3 [Certificate history:](#)  
Status: **Current** Issue No: 0  
Date of Issue: 2023-09-28  
Applicant: **MP Gamma S.r.l.**  
Via Cisa Ligure, 43/A  
Brescello (RE) 42041  
Italy  
Ex Component: Empty enclosures type: CPN ... lx U or SDN ... lx U  
*This component is NOT intended to be used alone and requires additional consideration when incorporated into other equipment or systems for use in explosive atmospheres (refer to IEC 60079-0).*  
Type of Protection: **Increased safety 'eb'; Protection by enclosure 'tb'**  
Marking: **Ex eb IIC Gb**  
**Ex tb IIIC Db**

Approved for issue on behalf of the IECEX  
Certification Body:

Marino Kelava



Position:

Certification Signatory

Signature:  
(for printed version)

Date:  
(for printed version)

2023-09-28

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**Fiditas Ltd**  
Slavka Tomerlina 44  
HR-10361 Zagreb-Sesvete  
Croatia



**Fiditas**  
explosion safety solutions



# IECEX Certificate of Conformity

Certificate No.: **IECEX FIDI 23.0007U**

Page 2 of 3

Date of issue: 2023-09-28

Issue No: 0

Manufacturer: **MP Gamma S.r.l.**  
Via Cisa Ligure, 43/A  
Brescello (RE) 42041  
Italy

Manufacturing  
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

## STANDARDS :

The component and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"  
Edition:2

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

## TEST & ASSESSMENT REPORTS:

A sample(s) of the component listed has successfully met the examination and test requirements as recorded in:

Test Report:

HR/FIDI/ExTR23.0001/00

Quality Assessment Report:

HR/FIDI/QAR23.0001/00



# IECEX Certificate of Conformity

Certificate No.: IECEX FIDI 23.0007U

Page 3 of 3

Date of issue: 2023-09-28

Issue No: 0

## Ex Component(s) covered by this certificate is described below:

Empty Enclosures model CPN lx U, SDN lx U with or without flanges. Enclosures made on stainless steel materials AIS304 or AIS316L. Depending on dimensions, walls and covers thickness may be 1.2 mm, 1.5 mm, 2.0 mm, or 3.0 mm differentiating box enclosure and cover. The enclosures incorporate holes for cable entries and also holes on the cover for installation of different accessories.

Dimension (mm) Up to 800×1200×400 for CPN enclosures  
Up to 400×400×150 for SDN enclosures

Service temperature: -50°C to +100°C

Ingress protection: IP 66

For each type of enclosure, CPN series or SDN series, temperature measurement performed and temperature coefficient (Rth) of an enclosure determined which define relationship between temperature of air inside box and dissipated power. Depends of externa dimension of an enclosure Rth can be calculated with formula:

$$R_{th} = A \times (\text{enclosure surface in mm}^2 \text{ except bottom surface})^B$$

Leged: **Rth** – Thermal resistance [K/W].

**A** and **B** - coefficients determined by measurement for each series of enclosure.

Enclosure type	Coeff A	Coeff. B
SDN	17149	-0.777
CPN	27186	-0.987

## SCHEDULE OF LIMITATIONS:

- Enclosures are Ex component, not intended to be used alone and requires additional consideration by the conformity assessment procedure when incorporated into Ex equipment.
- Enclosures are suitable for the service temperature -50°C to +100°C.